



中国认可
国际互认
检测
TESTING
CNAS L1020

国家强制性产品认证 试验报告

■新申请 □变更 □监督 □复审 □其他:

申请编号: A2019CCC0302-3267684

(任务编号)

产品名称: 熔断器式隔离开关

型 号: HR17N-630/30,HR17N-630/31,
HR17N-630/30M,HR17N-630/31M,
HR17N-630/30H,HR17N-630/31H,
HR17N-630/30MH,HR17N-630/31MH

检测机构: 苏州电器科学研究院股份有限公司



<p>样品名称: 熔断器式隔离开关</p> <p>型 号: HR17N-630/30, HR17N-630/31, HR17N-630/30M, HR17N-630/31M, HR17N-630/30H, HR17N-630/31H, HR17N-630/30MH, HR17N-630/31MH</p> <p>商 标: /</p> <p>样品数量: 10 台</p> <p>样品来源: 工厂送样</p> <p>收样日期: 2019-08-06</p> <p>完成日期: 2019-09-18</p>	<p>委托人: 浙江天正电气股份有限公司</p> <p>委托人地址: 浙江省乐清市柳市镇苏吕 工业 区</p> <p>生产者: 浙江天正电气股份有限公司</p> <p>生产者地址: 浙江省乐清市柳市镇苏吕 工业 区</p> <p>生产企业: 浙江天正电气股份有限公司</p> <p>生产企业地址: 浙江省乐清市经济开发 区中心大道 288 号</p>
--	---

试验结论: 依据 GB/T14048.3-2017 检验合格

本申请认证单元所覆盖的产品型号规格及相关情况说明:

HR17N-630/30, HR17N-630/31, HR17N-630/30M, HR17N-630/31M,
HR17N-630/30H, HR17N-630/31H, HR17N-630/30MH, HR17N-630/31MH

Ui:1000V; Uimp:12kV; Ue: AC415V/690V;

Ith=Ie:315A, 400A, 500A, 630A;

Iq:100kA(415V), 50kA(690V);

使用类别:AC-23B(415V), AC-22B(690V);


极数:3P;


配用的辅助触头: 一常开一常闭(2002010305025051)


型号:JW2-11;lth:3A

AC-15:AC220V,0.5A;

DC-13:DC220V,0.1A.

主检: 朱文华 签字:  日期: 2019-10-22

审核: 陆维导 签字:  日期: 2019-10-22

签发: 陈 源 签字:  日期: 2019-10-22



备注:

- HR17N-630/31H: Ue415V/630A:#01#09
- HR17N-630/30H: Ue690V/630A:#02#03#05#08
- HR17N-630/30H: Ue415V/630A:#04#06
- HR17N-315/30H: Ue415V/315A:#07
- HR17N-630/30M: Ue690V/630A:#10