

产品认证证书

II型自愿认证

证书编号: CQC2015010301813467

发证日期: 2020年09月22日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江天正电气股份有限公司
及生产地址 浙江省乐清市柳市镇柳乐路 332 号

产品名称和系列、规格、型号 综合配电箱 (低压成套开关设备)
TGJP2 主母线:InA=630A~100A,Icw=15kA;Ue=380V,Ui=690V;122kvar~10kvar,单相、三相结合补偿;50Hz;IP44,户外型;控制投切电容器的元件类型:复合开关

产品标准和技术要求 GB/T15576-2008;GB/T7251.12-2013

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人 签发

陈昕 陆楠



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0057896

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010301813467

Valid from: Sep.22,2020

Valid until:May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China

NAME AND LOCATION OF THE FACTORY Zhejiang Tengen Electrics Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage Switchgear Assemblies
TGJP2 主母线:InA=630A~100A,Icw=15kA;Ue=380V,Ui=690V;122kvar~10kvar,单相、三相结合补偿;50Hz;IP44,户外型;控制投切电容器的元件类型:复合开关

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T15576-2008;GB/T7251.12-2013

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY
陈昕
SIGNATURE
陆楠



CHINA QUALITY CERTIFICATION CENTRE

