

CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240303009025

Product Moulded Case Circuit-breakers

Applicant Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TeM5ED-125L, TeM5ED-125M, TeM5ED-125H,
TeM5ED-250L, TeM5ED-250M, TeM5ED-250H;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2023CQC0303-014203, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Aug.05,2024

Valid until: Aug.04,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE240303009025

TeM5ED-125L, TeM5ED-125M, TeM5ED-125H, TeM5ED-250L, TeM5ED-250M, TeM5ED-250H,

Ui: 1000V;

Uimp: 8kV;

Ue: AC380/400/415V;

In: Type 125L, 125M, 125H:63A~125A (adjustable),

Type 250L, 250M, 250H:100A~250A(adjustable);

Type of over-current release: Electronic;

Ics:35kA(L), 50kA(M), 65kA(H) ;

Icu:50kA(L), 50kA(M), 85kA(H) ;

Icw:3kA/1s;

Selectivity category:A;

Poles:3P,3P+N(3 protected poles with an uninterrupted neutral pole);

Applicable for isolation(except 3P+N(3 protected poles with an uninterrupted neutral pole));

50/60Hz;

IP20;

Auxiliary contacts (OF-M), Alarm contact(SD-M):1NO1NC,2NO2NC,4NO4NC;

Ith:3A;

AC-15:Ue/Ie:AC380/400/415V/0.3A;

DC-13:Ue/Ie:DC110V/DC220/250V/0.15A



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE